



DIVISION OF INDUSTRY SERVICES  
Plumbing Product Review  
P.O. Box 7302  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Governor Scott Walker      Laura Gutierrez, Secretary

October 9, 2018

TUF-TITE INCORPORATED  
HARRY PLANDER/TED MEYERS  
1200 FLEX COURT  
LAKE ZURICH IL 60047

Re: Description:      SEWAGE TANK COVERS, LIDS, RISERS  
Manufacturer:      TUF-TITE INCORPORATED  
Product Name:      (trans id 3165753) SEPTIC TANK RISER AND LID  
Model Number(s):      24-INCH RISER AND LID  
Product File No:      20180240

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of October 2023.


This approval supersedes the approval issued on May 21, 2013 under product file number 20130080.

This approval is contingent upon compliance with the following stipulation(s):

- The manhole cover must be secured to the riser using non-standard screws which are not slotted or Phillips head to be considered an effective locking device.
- Joints between riser sections shall be sealed with butyl mastic sealant and secured with a minimum of four screws.

The department is in no way endorsing this product or any advertising and is not responsible for any situation which may result from its use.

Sincerely,

  
Glen W. Schlueter  
Plumbing Product Reviewer  
Department of Safety and Professional Services  
Division of Industry Services  
Bureau of Technical Services  
(608) 267-1401 Phone  
(608) 267-9723 Fax  
glen.schlueter@wi.gov E-mail