



BILL CLINTON  
GOVERNOR

## *Arkansas* DEPARTMENT OF HEALTH

4815 WEST MARKHAM STREET • LITTLE ROCK, ARKANSAS 72205-3867  
TELEPHONE AC 501 661-2000

BEN N. SALTZMAN, M.D.  
DIRECTOR

May 27, 1986

Ted Meyers  
501 W. Algonquin Rd.  
Mt. Prospect IL 60056

RE: Tuf-Tite 5 Hole Distribution Box

Dear Mr. Meyers

We have reviewed a model of the above referenced distribution box and found it ~~conforming~~ to the general design and materials standards established for distribution boxes. Conditioned approval for low pressure distribution is issued for its use in this state and after a performance record is established over-all approval will be given.

Due to the light weight and shape of this unit we would recommend through instructions be developed for installation and back filling to prevent shifting and causing uneven distribution.

If this office can be of service in the future, please contact us.

Sincerely

A handwritten signature in cursive script that reads "Neal Glover".

Neal Glover, R.S., Prog. Administrator  
General Sanitatio Section  
Division of Sanitarian Services  
501/661-2171

NG:dlt  
cc: Gen. San. Staff