

RECEIVED AUG 19 2004

COUNTY OF PLACER
DEPARTMENT OF HEALTH AND HUMAN SERVICES

RICHARD J. BURTON, M.D., M.P.H.
DIRECTOR AND HEALTH OFFICER



ENVIRONMENTAL HEALTH DIVISION

BRAD BANNER, R.E.H.S.
ENVIRONMENTAL HEALTH DIRECTOR

August 9, 2004

Tuf-Tite Inc.
500 Capital Drive
Lake Zurich, IL 60047

Attn: Mr. Howard Cheezum

Re: Review of Tuf-Tite Riser assembly and D boxes

Dear Mr. Cheezum:

This division has reviewed the information presented to us on the Tuf-Tite Riser assembly (24" x 18" type III HDPE) and the D boxes (HDPE 7 Hole D box and 4 Hole D Box). The above products are acceptable for use in Placer County provided they are installed per the manufacturer's instructions.

The optional riser attachment for the D boxes are not approved for use in Placer County at this point in time as there does not appear to be a method to securely bolt the lid of this riser attachment to the riser itself.

If you have any further questions regarding the above, please call me at this office.

Sincerely,

A handwritten signature in blue ink, appearing to read "Mohan Ganapathy", is written over a horizontal line.

Mohan Ganapathy, R.E.H.S.
Land Use and Water Resources Section

REPLY TO OFFICE CHECKED

□ 11454 B AVENUE, AUBURN, CA 95603, (530) 745-2300, FAX (530) 745-2370

□ P.O. BOX 1909, TAHOE CITY, CA 96145, (530) 581-6240