



CABINET FOR HUMAN RESOURCES

COMMONWEALTH OF KENTUCKY

FRANKFORT 40621-0001

DEPARTMENT FOR HEALTH SERVICES

December 5, 1991

Ted Meyers
Tuf-Tite, Inc.
8 A Hillside Drive
Lake Barrington, IL 60010

Dear Mr. Meyers:

Plans for your 9 hole distribution box have been received and reviewed by our office staff. Approval for this product as a level type distribution box has been granted. As a level type distribution box, this component is restricted to use on sites with slopes of one percent (1%) or less.

The Kentucky approval code has been assigned as follows. This number must be affixed to all boxes sold in Kentucky by print stencil or other permanent means.

Component

Code Number

Distribution Box (9 Outlets)
Model No. 9HD2

KY-PL8-071-L

This component will be added to our "approved" component list for statewide distribution.

Sincerely,

A handwritten signature in cursive script, reading "David Nichols".

David Nichols, Technical Consultant
Environmental Sanitation Branch
Division of Local Health

c: All local health departments