



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL RESOURCES

Post Office Box 2063
Harrisburg, Pennsylvania 17105-2063
July 5, 1991

717-787-8184

Bureau of Water Quality Management

Ted Myers
Tuf-Tite, Inc.
8A Hillside Drive
Barrington, IL 60010

Dear Mr. Myers:

We reviewed the information and evaluated the sample of the new Tuf-Tite, 9-hole plastic distribution box for compliance with Chapter 73, Standards for Sewage Disposal Facilities. This product, when equipped with the appropriate number and type of pipe seals, outlet plugs and either the custom-cast, concrete or the domed, reinforced plastic lid complies with Section 73.42(e), Gravity Distribution. Because of the relatively light weight of the unit, anchoring or stabilizing them against shifting may be necessary for some installations.

The Commonwealth of Pennsylvania does not approve or endorse proprietary products. This letter does not constitute and may not be construed or used as an endorsement or approval. Approval of all sewage system installations and system components are the responsibility of the Sewage Enforcement Officer for the local agency with jurisdiction over the site of the system installation.

Questions on this may be directed to me at the above number or address.

Sincerely,

John M. Murtha
On-Lot System and Alternative
Technology Section
Division of Permits and Compliance

