



**SAFETY & BUILDINGS DIVISION**

201 E. Washington Avenue  
P.O. Box 7969  
Madison, Wisconsin 53707

**State of Wisconsin  
Department of Industry, Labor and Human Relations**

---

February 9, 1996

TUF-TITE CORPORATION  
RUSSEL RYDIN  
1125 OLD RAND ROAD  
WAUCONDA IL 60084

Dear Mr. Rydin:

RE: Code Approval of Distribution Boxes

Distribution boxes manufactured by Tuf-Tite do not require Wisconsin Plumbing Product Approval. However, the joint used to connect pipes to these boxes must be watertight for 10 minutes when subject to 10.8 psig pressure.

Sincerely,

A handwritten signature in cursive script that reads "Daniel P. Jensen".

Daniel P. Jensen  
Plumbing Product Reviewer  
Products, Research and Support Section  
(608) 267-5265

DJ: