



**Jim Martin, Commissioner**

**Kathleen E. Toomey, M.D., M.P.H., Division Director**

Georgia Department of Human Resources • Division of Public Health • Environmental Health & Injury Control Branch  
2 Peachtree Street NW • Suite 16-227 • Atlanta, Georgia 30303-3186 • Tel: 404-657-6534 • Fax 404-657-6533

November 20, 2001

Mr. Ted Meyers, President  
Tuf-Tite, Inc.  
1125 Old Rand Rd.  
Wauconda, IL 60084

**RE: Approval for Tuf-Tite Septic Tank Effluent Filter model EF-4 and TB-4 Tee Baffle Septic Tank Effluent Filter Components.**

Dear Mr. Meyers,

In accordance with the Department of Human Resources Rules and Regulations for On-Site Sewage Management Systems, Chapter 290-5-26-.16, the Technical Review Committee has approved the use of the above-referenced effluent filter and filter component. Approval is hereby effective immediately.

This approval is granted based upon the printed materials submitted to the Technical Review Committee on your product, including specifications, materials and installation criteria. In addition, the referenced filter and filter component is certified by NSF as meeting the current American National Standards Institute/NSF International (ANSI/NSF) Standard 46, Section 10 "Filtration Devices for Residential Gravity Flow Septic Tank Systems". Any change in specifications, materials or installation criteria requires approval of the Technical Review Committee and the Department prior to use in the State of Georgia.

If you have any questions regarding this approval, please contact this office at 404-657-6534.

Respectfully,

Gregory R. Harless  
Public Health State Office Program Consultant  
Division of Public Health  
Environmental Health Section  
Land Use Program

/grh

cc: Jeff Gary, Director, Environmental Health Section  
Scott Uhlich, Director, Land Use Program  
District Environmental Health Directors  
Technical Review Committee