



**State of Vermont
Department of Environmental Conservation**

AGENCY OF NATURAL RESOURCES

Wastewater Management Division
103 South Main St., The Sewing Building
Waterbury, Vermont 05671-0405

Phone: (802) 241-3822

Fax: (802) 241-2596

May 2, 2008

Mr. Ted Meyers, President
Tuf-Tite, Inc.
1200 Flex Court
Lake Zurich, IL 60047

847-550-1011 (voice)
800-382-7009 (toll free)
847-550-8004 (fax)

Re: Tuf-Tite® Effluent Filters


Dear Mr. Meyers,

This letter is written in response to your e-mail of April 9, 2008 requesting approval of the EF-4 and EF-6 Effluent Filters manufactured by Tuf-Tite® Inc. in accordance with the Environmental Protection Rules, Chapter 1, Wastewater System and Potable Water Supply Rules. The Rules, which became effective on September 29, 2007, were prepared by the Wastewater Management Division of the Vermont Agency of Natural Resources, Department of Environmental Conservation.

Section § 1-904(c) of the Rules states that all septic tank installations shall include an effluent filter approved by the Secretary. The only requirement of the filter is that it shall prevent passage of solids larger in size than 1/8 inch. Based on the information you have submitted and an examination of the sample filter, it appears that the EF-4 and EF-6 Effluent Filters manufactured by Tuf-Tite® Inc. meets the requirements of the Rules and can therefore be used in septic tank installations in Vermont.

Please contact me at 241-3027 or at the address/phone number above if you have any questions.

Sincerely,


Roger Thompson, Jr.
Regional Office Programs Manager

