



September 24, 2003

Mr. Ted Myers
TUF-TITE, Inc.
500 Capital Drive
Lake Zurich, IL 60047

Re: ANSI/NSF Standard 46 Certification

Dear Ted,

I am writing to confirm that the NSF Certified Tuf-Tite EF-4 and EF-6 septic tank effluent filters have met all requirements of Certification under ANSI/NSF Standard 46. This includes:

1. Compliance to the performance requirements of Section 10 of Standard 46.
2. Compliance to the product literature requirements of Standard 46.

The EF-4 effluent filter is certified for a flow range of 400-800 gpd (see Test #504035-01) and the EF-6 effluent filter is certified for a flow range of 400-1500 gpd (see Test #509759-03).

If you have any questions, please contact me at your convenience.

Sincerely,

A handwritten signature in cursive script that reads "Adriana Greco".

Adriana A. Greco
Program Representative
Environmental & Research Services

734-913-5754 (Voice)
734-827-7788(Fax)
greco@nsf.org (E-mail)

cc: product specs (0E150)