



Jim Martin, Commissioner

Georgia Department of Human Resources • Division of Public Health • Kathleen E. Toomey, M.D., M.P.H., Director
2 Peachtree Street NW • Suite 15.470 • Atlanta, Georgia 30303-3142
404-657-2700 • FAX: 404-657-2715

November 6, 2003

ADDENDUM

Mr. Ted Meyers, President
TUF-TITE, Inc.
500 Capital Drive
Lake Zurich, IL 60047

Subject: Previously approved TUF-TITE Septic Tank Effluent Filter models EF-4 and EF-6 Combo Filters; TB-4 and TB-6 Tee Baffle Septic Tank Effluent Filter Components.

Dear Mr. Meyers:

In accordance with the Department of Human Resources Rules and Regulations for On-Site Sewage Management Systems, Chapter 290-5-26, the Department has previously approved the above-referenced effluent filter and filter component for use in the state of Georgia. The following inclusions to the approval are provided as update and clarification addenda:


- EF-4 effluent filter maximum flow rate at 800 GPD.
- EF-6 effluent filter maximum flow rate at 1500 GPD.
- Both TB-4 and TB-6 filter housing components outlet fittings accept either four-inch diameter Schedule 40 PVC or four-inch diameter ASTM-3034 (SDR 35) PVC pipe.

This approval is granted based upon the printed materials submitted to the Department referencing your product, including specifications, materials and installation criteria. In addition, the referenced filter and filter component is certified by NSF as meeting the current American National Standards Institute/NSF International (ANSI/NSF) Standard 46, Section 10 "Filtration Devices for Residential Gravity Flow Septic Tank Systems". Any change in specifications, materials or installation criteria requires approval of the Department prior to use in the State of Georgia.

You may obtain a list of approved septic tank manufacturers, on-site sewage management system installation contractors and septage pumping contractors from this office for your use.

If you have any questions regarding this approval, please contact this office at 404-657-6534 or via e-mail at: grharless@dhr.state.ga.us.

Respectfully,


Gregory R. Harless
Public Health State Office Program Consultant

Environmental Health Section
Land Use Program
Two Peachtree Street, NW
16th Floor, Suite 16.235
Atlanta, GA 30303-3186

cc: Scott Uhlich, Director, Land Use Program
District Environmental Health Directors