

AN BAYH, GOVERNOR
J C. BAILEY, M.D., STATE HEALTH COMMISSIONER

IANA STATE BOARD OF HEALTH
WEST MICHIGAN STREET
BOX 1964
ANAPOLIS, IN 46206-1964



INDIANA STATE BOARD OF HEALTH

AN EQUAL OPPORTUNITY EMPLOYER

March 25, 1992

Ms. Joan Kutch
Country Septic Tanks
802 North Meridian Road
Valparaiso, IN 46383

Dear Ms. Kutch:

Re: Gas Deflection Baffle

This letter confirms receipt of your letter dated March 19, 1992, along with photos and the sample gas deflection baffle manufactured by Tuf-Tite, Incorporated. These items were received on March 25, 1992.

The use of this baffle installed on the outlet sanitary tee is acceptable as long as the bottom of the baffle faces the adjacent wall of the septic tank rather than facing towards the center of the tank. In other words, install the baffle 180 degrees opposite of the position shown in the pictures.

If you have any questions regarding these comments, please contact me at the number listed below.

Very truly yours,

BENJAMIN R. HIPPENSTEEL, P.E., CHIEF
PLAN REVIEW SECTION
DIVISION OF SANITARY ENGINEERING
AC 317/633-0177

BRHippensteel
cc: Porter County Health Department