



**SAFETY & BUILDINGS DIVISION**

201 E. Washington Avenue  
P.O. Box 7969  
Madison, Wisconsin 53707

**State of Wisconsin  
Department of Industry, Labor and Human Relations**

---

February 9, 1996

TUF-TITE CORPORATION  
RUSSEL RYDIN  
1125 OLD RAND ROAD  
WAUCONDA IL 60084

Dear Mr. Rydin:

RE: Code Approval of Gas deflectors

Gas deflectors manufactured by Tuf-Tite do not require Wisconsin Plumbing Product Approval as long as Tuf-Tite states the gas deflector are made for use in private sewage tanks. Also, the method of connecting the gas deflectors to the tank must be made to with corrosion resistant materials.

Sincerely,

A handwritten signature in cursive script, reading 'Daniel P. Jensen'.

Daniel P. Jensen  
Plumbing Product Reviewer  
Products, Research and Support Section  
(608) 267-5265