



April 13, 1988

Mr. Ted Meyers, President  
Tuf-Tite, Inc.  
8 A Hillside Drive  
Lake Barrington, Illinois 60010

Dear Mr. Meyers:

The Environmental Health Section, Georgia Department of Human Resources, has no objections to the use of Tuf-Tite's "Speed Leveler" in on-site sewage system distribution boxes in this state. You will recall that in an earlier telephone conversation you were informed that the state office does not issue statewide approval of products or materials used for on-site sewage disposal systems; this is a responsibility of each county board of health and local health departments.

The "Speed Leveler" is a simple, quick, and easily installed device which appears to have no objectionable qualities as long as it is used with smooth wall 4 inch drain tile and there is no significant leakage between the seal and the drain tile.

If we can be of further service to you or your Georgia representatives, please contact us at (404) 894-6644.

Sincerely,


Wilton O. Garrett  
Program Manager  
Environmental Health Section

WOG:nb


cc: District Environmentalists

Mr. Ray Durham  
Durham and Taylor Supply Company  
3996 Canton Highway  
Cumming, Georgia 30130


# TUF-TITE<sup>TM</sup>



- (1) INSTALL D-BOX AS USUAL, SHOULD BE APPROXIMATELY LEVEL.
- (2) INSERT A SPEED LEVELER IN EACH OUTLET PIPE.\*
- (3) ROTATE OFF CENTER HOLE TO THE 9 O'CLOCK POSITION.
- (4) FILL D-BOX WITH WATER, UNTIL WATER LEVEL REACHES GRIPPER TEETH OF SPEED LEVELER IN HIGHEST HOLE.
- (5) IF WATER OVERFLOWS THROUGH OFF CENTER HOLE BEFORE REACHING BOTTOM OF GRIPPER TEETH ON HIGHEST HOLE, BOX IS MORE THAN 5/8" OUT OF LEVEL AND BOX SHOULD BE RELEVELLED.
- (6) ROTATE SPEED LEVELERS BACK TOWARD 6 O'CLOCK POSITION UNTIL OFF CENTER HOLES ARE ABOUT 1/16" ABOVE WATER LEVEL.
- (7) ADD WATER TO BOX VERY SLOWLY, UNTIL DUE TO SURFACE TENSION, WATER LEVEL IS ACTUALLY HIGHER THEN OUTLET OPENINGS.
- (8) AT THIS POINT OUTLET OPENINGS SHOULD BE WITHIN .010" OF EACH OTHER.



\* FITS ALL 4" SMOOTH WALL PIPES.



Rt. 11, Box 405-B  
Cumming, Georgia 30130  
Cumming Atlanta  
889-4256 681-1265

**Durham  
& Taylor  
Supply  
Co, Inc**

