

H. H. HOLMES TESTING LABORATORIES, INC.

• 170 Shepard Avenue • Wheeling, Illinois 60090 • 847-541-4040 • Fax 847-537-9098



Report No. 3128.7-3
Re: TS-4 Pro Seal
Date of Test: 10/4/05

Date of Report: 10/17/05

TESTING CONDUCTED FOR: Tuf-Tite, Inc.
500 Capital Drive
Lake Zurich, IL 60047

Attn.: Ted Meyers


ITEMS TESTED: 4" Wiper Type Seal (P/N TS-4 Pro) using Schedule 40 pipe
as a medium

OBJECT OF TEST: To determine the ability of the unit to maintain vacuum

TEST PROCEDURE: Testing conducted at vacuum at test conditions:
70+/-5° F and Ambient RH

FINDINGS: Unit maintained seal with-out evidence of leakage for a period of 15 minutes
at 10 inches of Mercury
Test terminated at 15 minutes
Testing conducted at client premise with H.H. Holmes testing representative
present

Respectfully submitted,


Scott R. Nelson
President




Douglas Diefenthal, PE