



State of Idaho
DEPARTMENT OF HEALTH AND WELFARE
Division of Environmental Quality

1410 N. Hillon
Boise, Idaho 83706

CECIL D. ANDRUS
Governor

RICHARD P. DONOVAN
Director

September 17, 1990

MEMORANDUM

TO: Panhandle District Health Department,
Ken W. Lustig, Director of Environmental Health,
North Central District Health Department,
Paul E. Guenther, Director of Environmental Health,
Southwest District Health Department,
Tom Goss, Director of Environmental Health,
Central District Health Department,
Tom N. Turco, Director of Environmental Health,
South Central District Health Department,
Terry Schultz, Director of Environmental Health,
Southeastern District Health Department,
Jack Palmer, Director of Environmental Health,
District 7 Health Department,
Richard Horne, Director of Environmental Health

FROM: Barry N. Burnell, EHS
On-site Coordinator

SUBJECT: Composting Toilet and TUF-TITE Septic Tank Seal Approvals

The National Sanitation Foundation has certified for use the Sun-Mar Corporation's composting biological toilet, Model Sun-Mar X.L. The Sun-Mar X.L. biological toilet is an aerobic composting device with a maximum design rated capacity for full-time use by four persons. By means of a composting pile the unit provides for continuous treatment of human and food wastes. The NSF announcement is available through my office upon request.

TUF-TITE of Barrington, Illinois, has been marketing in the Panhandle Health District a septic tank inlet-outlet pipe seal. After review of the regulations, product literature and product sample, it has been determined that the TUF-TITE TS4 pipe seal is an acceptable product for use as an in-place pre-cast septic tank inlet and outlet pipe seal. Enclosed for your information is a one page product information sheet.

BNB/ps

Enclosure



Printed on Recycled Paper